

Minutes of Pre-Bid Meeting

07.01.2025

Subject: Minutes of Pre-Bid Meeting of “Maintenance and reconstruction of the collapsed compound wall of KINFRA Petrochemical Park Ambhalemugal Kochi.”

Tender No. - KINFRA/TCP/35/2024-25
Date of Pre-Bid Meeting - 07.01.2025, Tuesday at 10.30 a.m.
Location - KINFRA Petrochemical Park Site Office, Ambalamughal

Maintenance and reconstruction of the collapsed compound wall of KINFRA Petrochemical Park Ambhalemugal Kochi at KINFRA office on 07.01.2025 at 10.30 am.

Participants: -




Sl. No.	Name	Company / Firm
KINFRA Representatives		
1	Shine A	Junior Manager, Civil, KINFRA
2	Aravind M S	Project Executive, KINFRA
Participants		
1	Shijan K George	Private Contractor
2	O.M Mathew	Private Contractor

Minutes of Meeting

1. Mr. Shijan K. George inquired about the possibility of using a 15 cm brick in place of the 20 cm brick specified in item number 1.2. The Project Executive informed that the specifications as outlined in the Bill of Quantities (BOQ) cannot be altered and asked to follow the same.
2. For the construction of compound wall in the foundation existing areas, the existing foundation to be repaired, patched and the voids needs to be filled with stone chips and covered with cement Mortar in ratio 1:6 and above it 3 cm thick concrete mix in the ratio 1:3:6 needs to be provided. Above this the brick work needs to be commenced
3. Plinth beam need not be provided above the RR foundation
4. The typical cross section drawing for the compound wall that is to be newly constructed and to be reconstructed above the existing RR foundation shall be provided

-----end of meeting-----

Maintenance and reconstruction of Collapsed Compound Wall of KINFRA Petrochemical Park, Ambalamughal, Kochi



All dimensions in CM